



1. New flashing dressed under roofing felt.
2. Thermal insulation with $R > 0.60 \text{ m}^2\text{K/W}^*$
3. Gutter refixed over flashing: Re-connected to neighbouring shared gutter
4. Waterproof membrane fixed to wall & dressed over EWI system wall
5. Joint clips between adjoining sections
6. Face width min. 40 mm (increase in severe/v. severe exposure locations)
7. 40 mm projection. 50 mm in severe/v.severe exposure locations?

*Insulation type/thickness	R
20 mm EPS ($\lambda = 0.030 \text{ W/mK}$)	R = 0.666 $\text{m}^2\text{K/W}$
22 mm EPS ($\lambda = 0.034 \text{ W/mK}$)	R = 0.647 $\text{m}^2\text{K/W}$
10 mm Aerogel ($\lambda = 0.030 \text{ W/mK}$)	R = 0.625 $\text{m}^2\text{K/W}$

DRAWING TITLE: Scenario 1 –Solution A – Flashing with separate gutter



DRAWING No: EP-061

DATE: 09-02-2022

SCALE: NTS

REFERENCES:

EWI Pro Insulation Systems LTD.
 Kingston Bussines Centre Unit1
 Fullers Way South
 Chessington KT9 1DQ